

Mr. C. S. Haugh, P.E.
Chief, Source Surveillance
New York State Department of Environmental Conservation
Division of Water
Bureau of Watershed Programs
625 Broadway, 4th Floor
Albany, New York 12233-3506

AC-EA
WR:2015:0011
March 4, 2015

SUBJECT: State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR)
for the Period February 1 through February 28, 2015, SPDES Permit No. NY-0000973, West
Valley Demonstration Project (WVDP)

Dear Mr. Haugh:

The West Valley Demonstration Project's SPDES DMR for the reporting period February 1 through February 28, 2015, including the Net Iron concentration sheet, is attached.

Please note there was no discharge at outfall 001, 007, 116, Sum-N, or internal outfall 01B during this period.


Please also note that as of September 15, 2014 the site transitioned from withdrawing water from the reservoirs to supply the site's water needs (potable and industrial) to the use of two recently installed groundwater wells. This transition has eliminated several functions within the utility room, (i.e., sand filter backwashes and clarifier blowdowns) thereby significantly reducing, or eliminating entirely, the discharge from outfall 007.

The change to groundwater wells also eliminated the need to collect raw water samples on a weekly basis for the analysis of iron and will alter the iron discharge concentration equation as the mass of raw water entering the system will no longer be calculated.

As required in Title 6 of the New York Codes, Rules, and Regulations (6NYCRR) Part 750-2.5(e)(3), the New York Environmental Laboratory Accreditation Program (NYELAP) identification numbers for the laboratories performing are normally required; however, the WVDP did not have any sample analysis completed for this DMR.

If you have any questions, please contact Moira Maloney of the U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP) at (716) 942-4255 or William Kean of my staff at (716) 942-4865.

Sincerely,



John D. Rendall, Manager
Regulatory Strategy

JDR:WNK:bnj

Attachment: SPDES DMR for February 1 through February 28, 2015 Monitoring Period

cc: M. A. Jackson, NYSDEC-Region 9 DOW
E. W. Wohlers, Cattaraugus County Health Department
J. M. Dundas, DOE-WVDP
M. N. Maloney, DOE-WVDP
J. J. Baker, CHBWV
L. E. Bennett, CHBWV (Public Reading Room)
R. M. Geimer, CHBWV
W. N. Kean, CHBWV
J. D. Rendall, CHBWV
R. L. Scharf, CHBWV
A. W. Upshaw, CHBWV
B. N. Jeffery (Letter Log), CHBWV

ATTACHMENT

SPDES DISCHARGE MONITORING REPORT - FEBRUARY 1 THROUGH FEBRUARY 28, 2015
NET IRON EFFLUENT CONCENTRATION CALCULATION
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT NO. NY-0000973

$$\text{OUTFALL 001} = M1 = \frac{(X1 + X2) V1}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V1 = 0.00 \text{ L/month}$$

*Note: There was no Discharge at outfall 001 during this monitoring period.

$$\text{OUTFALL 007} = M7 = \frac{(X1 + X2) V7}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V7 = 0.00 \text{ L/month}$$

*Note: There was no Discharge at outfall 007 during this monitoring period.

$$\text{RAW WATER} = \text{MRW} = \frac{(X1 + X2 + X3 + X4) \text{VRW}}{4} = 0.00 \text{ mg/month}$$

$$X1 = 0.000 \text{ mg/L}$$

$$X2 = 0.000 \text{ mg/L}$$

$$X3 = 0.000 \text{ mg/L}$$

$$X4 = 0.000 \text{ mg/L}$$

$$\text{VRW} = 0.00 \text{ L/month}$$

*Note: Raw water from the reservoir system is no longer used for process water.

$$\text{IRON DISCHARGE CONCENTRATION} = \frac{M1 + M7 - \text{MRW}}{V1 + V7} = 0.00 \text{ mg/L}$$

DISCHARGE MONITORING REPORT (DMR)

CMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)

MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

MONITORING PERIOD

OUTFALL 001 MONTHLY PROC WW, GW, ST
External OutfallNo Discharge ☒

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Sulfate [as S]	*****	*****	*****	*****	*****	*****			
00154 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Once per Batch	COMP24
Oxygen demand, ultimate	*****	*****	*****	*****	*****	*****			
00181 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Twice per Batch	CALCTD
Oxygen, dissolved [DO]	*****	*****	*****	*****	*****	*****			
00300 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Twice per Batch	GRAB
BOD, 5-day, 20 deg. C	*****	*****	*****	*****	*****	*****			
00310 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Twice per Batch	COMP24
pH	*****	*****	*****	*****	*****	*****			
00400 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Once per Batch	GRAB
Solids, total suspended	*****	*****	*****	*****	*****	*****			
00530 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Twice per Batch	COMP24
Solids, settleable	*****	*****	*****	*****	*****	*****			
00545 10 Effluent Gross	*****	*****	*****	*****	Req. Mon. MO AVG	mL/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE	DATE
John D. Rendall, Manager	716-942-4602	03/02/2015
TYPED OR PRINTED	AREA Code	NUMBER
	716	942-4602
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		
MM/DD/YYYY		
MM/DD/YYYY		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, ST
External Outfall

No Discharge ☒

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
00556 1 0 Effluent Gross Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
00615 1 0 Effluent Gross Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
00620 1 0 Effluent Gross Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
00625 1 0 Effluent Gross Sulfide, dissolved, [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Twice per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Twice per Batch	COMP24
00746 1 0 Effluent Gross Arsenic, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
00978 1 0 Effluent Gross Cobalt, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	COMP24
00979 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE		DATE
John D. Rendall, Manager	716-942-4602	03/02/2015	
TYPED OR PRINTED	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, ST
External Outfall

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

No Discharge ☒

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Selenium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Once per Batch	GRAB
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Twice per Batch	COMP24
Aluminum, total [as Al]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
01105 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Once per Batch	COMP24
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Vanadium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
01128 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Once per Batch	GRAB
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Twice per Batch	COMP24
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Twice per Batch	CONTIN
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****			Once per Batch	GRAB
	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE		DATE
John D. Rendall, Manager	716-942-4602		03/02/2015
TYPED OR PRINTED	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U S DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
 LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

DMR Mailing ZIP CODE: 14171-9799
 MAJOR
 (SUBR 09)


OUTFALL 001 MONTHLY PROC WW, GW, ST
 External Outfall

No Discharge ☒

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
70295 10 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Twice per Batch	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****					
71900 10 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	50 MO AVG	ng/L		Once per Batch	GRAB
Surfactants [linear alkylate sulfonate]	SAMPLE MEASUREMENT	*****	*****	*****	*****					
81646 10 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE		DATE
John D. Rendall, Manager	716-942-4602		03/02/2019
TYPED OR PRINTED	AREA Code	NUMBER	MM/DD/YYYY
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 			

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

CMB No 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 05)

MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

SANITARY, NC COOLING WATER, UTILITY V
External OutfallNo Discharge ☒

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L		Monthly	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	3 MINIMUM	mg/L		Twice per Month	GRAB
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	6.5 MINIMUM	SU		Twice per Month	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****				
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information on which this document is based. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			TELEPHONE	DATE
John D. Rendall, Manager	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			716-942-4602	03/02/2015
TYPED OR PRINTED				AREA Code	NUMBER
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)					MM/DD/YYYY

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
SANITARY, NC COOLING WATER, UTILITY W
External Outfall

MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

MONITORING PERIOD

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS				
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****						
	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L	.1 DAILY MX	Monthly	COMP24	
00625 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L	Req. Mon. DAILY MX	Monthly	COMP24	
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L	Req. Mon. DAILY MX	Twice per Month	COMP24	
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	1.49 MO AVG	mg/L	2.1 DAILY MX	Twice per Month	COMP24	
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****						
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****						
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****						
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L	.1 DAILY MX	Monthly	GRAB	
	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	mg/L	Req. Mon. DAILY MX	Twice per Month	GRAB	
	SAMPLE MEASUREMENT	*****	*****	*****	*****						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE	DATE
John D. Rendall, Manager	716-942-4602	03/02/2015
TYPED OR PRINTED	AREA Code	NUMBER
	716	942-4602
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		
MM/DD/YYYY		
MM/DD/YYYY		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U S DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007-M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
SANITARY, NC COOLING WATER, UTILITY V
External Outfall

No Discharge ☒

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	VALUE	UNITS	VALUE	UNITS			
Mercury, total [as Hg]	*****	*****	*****	*****				
71900 1 0 Effluent Gross	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
John D. Rendall, Manager	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		716-942-4602	03/02/2015
TYPED OR PRINTED			AREA Code NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	01B-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
MERCURY PRETREATMENT
Internal Outfall

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

No Discharge ☒

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Flow rate					*****	*****	*****			
00056 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****		Weekly	CONTIN
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****			
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	50 DAILY MX	ng/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John D. Rendall, Manager		716-942-4602		03/02/2015
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)		AREA Code	NUMBER	MM/DD/YYYY
		716	942-4602	03/02/2015

DISCHARGE MONITORING REPORT (DMR)

DMR No 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	116-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)
PSEUDO MON. POINT @FRANKS CRK
Internal Outfall

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2015	2/28/2015

No Discharge ☒

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	VALUE	UNITS	VALUE	VALUE	UNITS			
Solids, total dissolved	*****	*****	*****	*****					
70295 Z 0 Instream Monitoring	*****	*****	*****	*****	500 DAILY MX	mg/L		Twice per Discharge	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
John D. Rendall, Manager TYPED OR PRINTED		716-942-4602 AREA Code NUMBER	03/02/2015 MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

IF PSEUDO MONITORING POINT REPORT IS NOT REQUIRED DURING THE MONITORING PERIOD, EITHER CHECK THENO DISCHARGE BOX OR ENTER 'NODI' IN PLACE OF A MEASUREMENT TO INDICATE A GENERAL PERMIT EXEMPTION.

DISCHARGE MONITORING REPORT (DMR)

OMB No 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	SUM-N
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR (SUBR 09)SUM OF OUTFALLS 1 & 7
Internal OutfallNo Discharge ☒

MONITORING PERIOD
MM/DD/YYYY
2/1/2015

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	VALUE	UNITS			
Iron, total [as Fe]	*****	*****	*****					
01045 2 0 Effluent Net	*****	*****	*****	Req. Mon. MO AVG	1 DAILY MX		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	TELEPHONE		DATE
John D. Rendall, Manager	716-942-4602		03/02/2015
TYPED OR PRINTED	AREA Code	NUMBER	MM/DD/YYYY
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

CORRESPONDENCE CONTROL SHEET

Correspondence Code WR : 2015 : 0011	Author's Name & Extension William Kean/4865	Date Review Submitted 03/02/15	Date Review Due 03/02/15	File Series Code
Subject State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR) for the Period February 1 through February 28, 2015, SPDES Permit No. NY-0000973, West Valley Demonstration Project (WVDP)				

Does this Correspondence Respond to any DOE or Regulator Correspondence?

☒ No
☐ Yes - If yes, then identify the following: Correspondence Code: _____ OITS Number: _____

Does this correspondence contain Official Use Only (OUO) information?

[i.e., information is certain unclassified information that may be exempt from public release under the Freedom of Information Act (FOIA), (Exemptions 3-9) and has the potential to damage governmental, commercial, or private interests if disseminated to persons who do not need to know the information to perform their jobs or other DOE authorized activities; refer to WVDP-402 for additional guidance on this determination.]

☒ No
☐ Yes - If yes, ensure the document(s) is properly stamped and marked as OUO per requirements of WVDP-402. If Administratively Confidential or Proprietary, documentation must also be properly marked as such per requirements of WVDP-402.

Does this correspondence contain ECI (OUO, FOIA Exemption 3)?

[i.e., technical information that would be restricted by statute; refer to WVDP-402 for guidance on this determination.]

☒ No
☐ Yes - If yes, ensure the document(s) is properly stamped and marked as ECI and OUO per requirements of WVDP-402 and Export Technology Control Officer (ETCO) or trained alternate signature & date are obtained on the document(s).

OUO Reviewer/ECI Screener or ECI Document Reviewer: _____



Printed Name/Signature

Funding Commitment

Does this correspondence commit funds?

☒ No
☐ Yes - If yes, then obtain Business Manager/CFO and Planning & Integration Manager review.

REVIEWER APPROVALS (only used for hard copy process)

Printed Name	Signature	Date	Approve	Approve w/Comments	Disapprove
WV-PL6/W. N. Kean		3/2/15	☒	☐	☐
AC-EA/J. D. Rendall		3-2-15	☐	☒	☐
AC-PROC/L. K. Hollfelder		3/2/15	☒	☐	☐
AC-DOE/J. M. Dundas		3/4/15	☒	☐	☐
			☐	☐	☐
			☐	☐	☐

Reviewer initial & date indicating satisfactory resolution of disapproved comments:
 (only used for hard copy process) _____