

CH2MHILL • BWXT West Valley, LLC

West Valley Demonstration Project

Mr. C. S. Haugh, P.E.
Chief, Source Surveillance
New York State Department of Environmental Conservation
Division of Water
Bureau of Watershed Programs
625 Broadway, 4th Floor
Albany, New York 12233-3506

AC-EA
WR:2016:0018
April 6, 2016

SUBJECT: State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR)
for the Period March 1 through March 31, 2016, SPDES Permit No. NY-0000973, West Valley
Demonstration Project (WVDP)

Dear Mr. Haugh:

The West Valley Demonstration Project's SPDES DMR for the reporting period March 1 through March 31, 2016, including the Net Iron concentration sheet, is attached.

Please note there was no discharge at outfall 001, 007, 116, Sum-N, or internal outfall 01B during this period.


Please also note that as of September 15, 2014 the site transitioned from withdrawing water from the reservoirs to supply the site's water needs (potable and industrial) to the use of two recently installed groundwater wells. This transition has eliminated several functions within the utility room, (i.e., sand filter backwashes and clarifier blowdowns) thereby significantly reducing, or eliminating entirely the discharge from outfall 007.

The change to groundwater wells also eliminated the need to collect raw water samples on a weekly basis for the analysis of iron and will alter the iron discharge concentration equation as the mass of raw water entering the system will no longer be calculated.

As required in Title 6 of the New York Codes, Rules, and Regulations (6NYCRR) Part 750-2.5(e)(3), the New York Environmental Laboratory Accreditation Program (NYELAP) identification numbers for the laboratories performing are normally required, however, the WVDP did not have any sample analysis completed for this DMR.

If you have any questions, please contact Moira Maloney of the U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP) at (716) 942-4255 or William Kean of my staff at (716) 942-4865.

Sincerely,



John D. Rendall, Manager
Regulatory Strategy & Chief Engineer

JDR:WNK:bnj

Attachment: SPDES DMR for March 1 through March 31, 2016 Monitoring Period

cc: M. A. Stein, NYSDEC-Region 9 DOW
E. W. Wohlers, Cattaraugus County Health Department
J. M. Dundas, DOE-WVDP
M. N. Maloney, DOE-WVDP
J. J. Baker, CHBWV
L. E. Bennett, CHBWV (Public Reading Room)
W. N. Kean, CHBWV
D. P. Klenk, CHBWV
R. L. Scharf, CHBWV
A. W. Upshaw, CHBWV
B. N. Jeffery (Letter Log), CHBWV

ATTACHMENT

SPDES DISCHARGE MONITORING REPORT - MARCH 1 THROUGH MARCH 31, 2016
NET IRON EFFLUENT CONCENTRATION CALCULATION
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT NO. NY-0000973

$$\text{OUTFALL 001} = M1 = \frac{(X1 + X2) V1}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V1 = 0.00 \text{ L/month}$$

*Note: There was no Discharge at outfall 001 during this monitoring period.

$$\text{OUTFALL 007} = M7 = \frac{(X1 + X2) V7}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V7 = 0.00 \text{ L/month}$$

*Note: There was no Discharge at outfall 007 during this monitoring period.

$$\text{RAW WATER} = MRW = \frac{(X1 + X2 + X3 + X4) VRW}{4} = 0.00 \text{ mg/month}$$

$$X1 = 0.000 \text{ mg/L}$$

$$X2 = 0.000 \text{ mg/L}$$

$$X3 = 0.000 \text{ mg/L}$$

$$X4 = 0.000 \text{ mg/L}$$

$$VRW = 0.00 \text{ L/month}$$

*Note: Raw water from the reservoir system is no longer used for process water.

$$\text{IRON DISCHARGE CONCENTRATION} = \frac{M1 + M7 - MRW}{V1 + V7} = 0.00 \text{ mg/L}$$

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, ST
External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Sulfate [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00154 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Twice per Batch	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice per Batch	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice per Batch	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Once per Batch	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Batch	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	mL/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John D. Rendall, Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			716-942-4602		04/04/2016
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040- 0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, ST
External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Once per Batch	GRAB
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once per Batch	COMP24
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	COMP24
Sulfide, dissolved, [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00746 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.4 DAILY MX	mg/L		Once per Batch	COMP24
Arsenic, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00978 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.15 DAILY MX	mg/L		Once per Batch	COMP24
Cobalt, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00979 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.005 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John D. Rendall, Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			716-942-4602		04/04/2016
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040- 0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, S1
External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Selenium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00981 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.004 DAILY MX	mg/L		Once per Batch	GRAB
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	COMP24
Aluminum, total [as Al]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01105 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	2 MO AVG	4 DAILY MX	mg/L		Once per Batch	COMP24
Vanadium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01128 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.014 DAILY MX	mg/L		Once per Batch	GRAB
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	1.5 MO AVG	2.1 DAILY MX	mg/L		Twice per Batch	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Twice per Batch	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John D. Rendall, Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			716-942-4602		04/04/2016
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, S1
External Outfall
No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	50 MO AVG	Req. Mon. DAILY MX	ng/L		Once per Batch	GRAB
Surfactants [linear alkylate sulfonate]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
81646 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.04 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
John D. Rendall, Manager		716-942-4602		04/04/2016		
TYPED OR PRINTED						
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)


Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY I
External Outfall
No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Monthly	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice per Month	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice per Month	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Twice per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Month	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	mL/L		Twice per Month	GRAB
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John D. Rendall, Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			716-942-4602		04/04/2016
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY &
External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	COMP24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Monthly	COMP24
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	COMP24
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	1.49 MO AVG	2.1 DAILY MX	mg/L		Twice per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Monthly	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	GRAB
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John D. Rendall, Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			716-942-4602		04/04/2016
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY

ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799

MAJOR

(SUBR 09)

SANITARY, NC COOLING WATER, UTILITY

External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John D. Rendall, Manager		716-942-4602		04/04/2016
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	01B- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
MERCURY PRETREATMENT
Internal Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow rate	SAMPLE MEASUREMENT				*****	*****	*****	*****			
00056 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Weekly	CONTIN
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		04/04/2016
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY

ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	116- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171- 9799

MAJOR

(SUBR 09)

PSEUDO MON. POINT @FRANKS CRK

Internal Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 Z 0 Instream Monitoring	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	500 DAILY MX	mg/L		Twice per Discharge	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John D. Rendall, Manager		716-942-4602		04/04/2016
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

IF PSEUDO MONITORING POINT REPORT IS NOT REQUIRED DURING THE MONITORING PERIOD, EITHER CHECK THE NO DISCHARGE BOX OR ENTER 'NODI A' IN PLACE OF A MEASUREMENT TO INDICATE A GENERAL PERMIT EXEMPTION.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	SUM- N
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
3/1/2016	3/31/2016

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SUM OF OUTFALLS 1 & 7
Internal Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Iron, total [as Fe] 01045 2 0 Effluent Net	SAMPLE MEASUREMENT	*****	*****	*****	*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	1 DAILY MX	mg/L		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		04/04/2016
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

CORRESPONDENCE CONTROL SHEET

Correspondence Code <u>WR : 2016 : 0018</u>	Author's Name & Extension William Kean/4865	Date Review Submitted 4/4/16	Date Review Due 4/14/16	File Series Code
Subject State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR) for the Period March 1 through March 31, 2016, SPDES Permit No. NY-0000973, West Valley Demonstration Project (WVDP)				

Does this Correspondence Respond to any DOE or Regulator Correspondence?

☒ No☐ Yes - If yes, then identify the following: Correspondence Code: _____ OITS Number: _____

Does this correspondence contain Official Use Only (OUO) information?

[i.e., information is certain unclassified information that may be exempt from public release under the Freedom of Information Act (FOIA), (Exemptions 3-9) and has the potential to damage governmental, commercial, or private interests if disseminated to persons who do not need to know the information to perform their jobs or other DOE authorized activities; refer to WVDP-402 for additional guidance on this determination.]

☒ No☐ Yes - If yes, ensure the document(s) is properly stamped and marked as OUO per requirements of WVDP-402. If Administratively Confidential or Proprietary, documentation must also be properly marked as such per requirements of WVDP-402.

Does this correspondence contain ECI (OUO, FOIA Exemption 3)?

[i.e., technical information that would be restricted by statute; refer to WVDP-402 for guidance on this determination.]

☒ No☐ Yes - If yes, ensure the document(s) is properly stamped and marked as ECI and OUO per requirements of WVDP-402 and Export Technology Control Officer (ETCO) or trained alternate signature & date are obtained on the document(s).OUO Reviewer/ECI Screener or ECI Document Reviewer: _____

Charles A. Biedermann/Charles A. Biedermann
Printed Name/Signature

Funding Commitment

Does this correspondence commit funds?

☒ No☐ Yes - If yes, then obtain Business Manager/CFO and Planning & Integration Manager review.

REVIEWER APPROVALS (only used for hard copy process)

Printed Name	Signature	Date	Approve	Approve w/Comments	Disapprove
William Kean	<i>W. A. Kean</i>	3/31/16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
C. A. Biedermann	<i>Charles A. Biedermann</i>	4/1/16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
John Rendall	<i>John Rendall</i>	3/31/16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lynn Hollfelder	<i>Lynn Hollfelder</i>	4/1/16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Jennifer Dundas	<i>Jennifer Dundas</i>	4/1/16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Reviewer initial & date indicating satisfactory resolution of disapproved comments:
(only used for hard copy process)